

Annex (1)
Communicable Disease Reporting Form

First: Patient's information		
Reporting date	:	
Number of health card	:	
ID / passport number or unified number	:	
Full name	:	
Date of birth	:	
Age	:	
Gender	:	
Nationality	:	
Residential address (emirate, city, district, street, building number, apartment number)	:	
Work phone number	:	

Mobile phone number	:	
Profession	:	
Work / study place	:	
Phone number of work / educational institution	:	
Sponsor's name (if any)	:	
Sponsor's mobile phone number (if any)	:	
Second: Information on the medical condition		
The date the disease starts	:	
Diagnosis (initial / confirmed)	:	
Laboratory examination (has / has not been carried out)	:	
Third: Information of the reporting person		

Name	:	
Occupation	:	
Contact number	:	

Table (a)
Levels of Isolation Rooms at hospitals

Isolation room level	Standard	Negative Pressure	Positive Pressure
Ventilation standards	There is no difference between the air pressure in the room and its surroundings	The air pressure in the room is less than the pressure in its surroundings	The air pressure in the room is more than the pressure in its surroundings
Precautions according to the transmission methods	Transmission through direct contact and drizzles	Transmission through air	To prevent the transmission of infection from outside to inside the isolation room
Examples of the diseases	<ul style="list-style-type: none"> - Antibiotic resistant bacteria like VREI - Viral Hemorrhagic Fever (VHF) - Intestinal Catarrh - Hepatitis - Meningitis - H1N1 	<ul style="list-style-type: none"> - Measles - Varicella - Tuberculosis - Middle East Respiratory Syndrome - Coronavirus 	Protection of patients suffering from low immunity from infection at hospitals

Table (b)
Minimum Technical Specifications Required in Isolation Rooms at
Hospitals

Technical specifications	Standard	Negative Pressure	Positive Pressure
Non hand operated basin in room and anteroom	Yes	Yes	Yes
In-suite bathroom (shower, toilet and hand washbasin)	Yes	Yes	Yes
Pan sanitizer (near room)	Optional	Optional	Optional
Door on room with door closer		Yes	
Anteroom		Yes	
Sealed room, door grille for controlled air flow		Yes	Yes

12 ACHR or 145 liters per patient		Yes	Yes
100% outside air ventilation		Yes	
Local differential pressure monitoring		Yes	Yes
Independent air supply		Yes	
HEPA filters on air supply		Yes	
Low level exhaust 150 mm above floor		Yes	Yes
Independent exhaust fan discharging vertically at 10 m/s		Yes	

Table (c)
High Risk Communicable Diseases

S. No.	Infectious disease
1	Lassa fever
2	Plague
3	Rabies
4	Viral Hemorrhagic Fever
5	Yellow Fever
6	Anthrax
7	Small Box
8	Creutzfeldt – Jacob Disease
9	Typhus

Table (d)
Dangerous Communicable Diseases

S. No.	Infectious disease
1	Hepatitis B
2	Hepatitis C
3	HIV
4	AIDS
5	SARI
6	Novel Coronavirus COVID-19
7	Middle East Respiratory Syndrome

Table (e)
Medium Risk Communicable Diseases

S. No.	Infectious disease
1	Acute Poliomyelitis
2	Avian Influenza
3	Cholera
4	Diphtheria
5	Dysentery (Amoebic or Bacillary)
6	Food borne diseases
7	Hepatitis (A) and (E)
8	Leptospirosis (Weil's)
9	Malaria
10	Meningococcal Disease
11	Paratyphoid Disease
12	Relapsing Disease
13	Scarlet Fever
14	Tuberculosis
15	Typhoid Disease
16	Acute Encephalitis
17	Leprosy
18	Measles
19	Meningitis (Non-Meningococcal)
20	Mumps
21	Ophthalmic Neonatorum
22	Rubella
23	Tetanus
24	Whooping Cough
25	Streptococcal Invasive Disease

